




# MUNICIPAL CORPORATION OF DELHI

OFFICE OF THE DY. HEALTH OFFICER : NAJAFGARH ZONE  
ROOM NO.408, 4<sup>TH</sup> FLOOR, ZONAL BUILDING, DHANSA STAND,  
NAJAFGARH, NEW DELHI 110043



No.DHO/NGZ/2024/ 577

Dated 22/07/2024

1. Name of the School **JINVANI BHARTI PUBLIC SCHOOL**
2. School Address **SECTOR-04, DWARKA, NEW DELHI-110078**
3. No. of Shift ONE Timing 08:00 AM TO 02:00 PM
4. No. of Students: Boys = 807 Girls = 635 Total = 1442
5. No. of Staffs: Male 0 Female 66 Total =66

## Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient SUFFICIENT
2. The Classrooms are Well Lighted/ ill lighted WELL LIGHTED
3. The Classrooms are Well Ventilated/ ill ventilated WELL VETILATED
4. The Classrooms are kept / Not kept Neat & Clean: NEAT AND CLEAN
5. The Classrooms/Building requires/ do not required Whitewash etc. NOT REQUIRED
6. The Drinking Water is Wholesome/ not wholesome WHOLESOME
7. The Latrine arrangement is Sanitary/ insanitary SANITARY FROM HEALTH POINT OF VIEW.

## No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is SUFFICIENT
2. One latrine for 40 male student is required so total is SUFFICIENT
3. Separate Toilet arrangement for staff present: Yes/No YES SEPARATE EXISTS FOR STAFF.
4. The Overall facilities: Good/ Adequate/Inadequate V.GOOD FROM HEALTH POINT OF VIEW AND VALID UP TO ONE YEAR FROM ISSUANCE DATE.

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

(Remark: Certificate is valid for one year)

*[Signature]*  
ANKUR TYAGI

Asst. Public Health Inspector  
Public Health Department  
Municipal Corporation Of Delhi

*[Signature]*

Deputy Health Officer  
Najafgarh Zone

**Deputy Health Office**  
Municipal Corporation Of Del  
Health Deptt., Najafgarh Zon